



Becky Dawes
Procurement Director

Bid 07-05-B, Sign Materials Q&A

Q: Is the bid requesting the price for the Street Name Sign Posts only?

A: Yes.

Q: Or, does it need the price for the Post, anchor, and bolt together?

A: No

Q. Please clarify the products spacing and sizes:

Is this a custom post?, typically post are drilled 1" on center, not one hole 5" from the end.

2" square post, solid, 14 gauge steel, galvanized.

Two, 3/8" (0.375 inches) holes required on adjacent faces of the post, centered at 5" from the end of the post.

A: Yes.

I spoke with 3M and they were not familiar with these dimensions. Are these custom lengths?

Green Film, 3M 1177C or equivalent, 46" x 100

Equivalent, 19" x 100 yards

A: Yes. Two, separate, 50 yard length rolls (for film and/or tape) may be substituted to create the total 100 yard length. Widths must be as specified.

Q: On page 2 of the specifications in the Sign Posts & Hardware section, do we need to include the price for the square anchor base and corner bolts in with price of the 2" x 10' posts?

A: No. We do not need the 2 1/4" square anchor bases and corner bolts at this time.

Q: would the county accept square posts that have holes punched on all four signs and the entire length of the posts?

A: No. The 2" square sign posts must be solid with two single holes as shown on DWG 0000-0002.